




BARTLETT Instrument Company

Do You Know How Long Your Greenhouse Heaters & Fans Run?

[Home](#) • [Controller Overview](#) • [GHK](#) • [RWL](#)



Did you know you could check your run time for your heaters and fans on your GHK12X2 and RWL11X2 controllers? With the newer versions of the GHK12X2 and RWL11X2, you can check the run time for your heats and cools. This can be helpful if you think one of your appliances is running too much, just check the run times to help make your determination.

You can also reset the run times back to zero whenever you'd like. You could compare run times from day to day or week to week. Just reset the times and track your data. If you are using CIS, you can view and reset your run times directly from your computer.

To check the run times on the RWL11X2 or GHK12X2 follow these steps:

- Press the "MENU" or "NEXT" button until RuNT appears in the display. You can use the CLOCK or BACK button to go through the Menu backwards.
- Press the "ENTER" button and RuNT will alternate with VIEW.
 - To view, press the "ENTER" button and the controller will go through a series of displays. First DAYS followed by the number of days since the last reset, then each appliance (CL 1, HT 1, etc.) and the number of hours after the appliance is displayed.

- To reset the run times, press the 1 button and the screen will alternate between RuNT and CLR. Press "ENTER" and the run times will be cleared.
- After you've reset or viewed your run times, the controller will revert back to the normal operating display.

Want to see your run times, but can't find the option on your controller? Give us a call to find out about how to upgrade your existing controllers!

BARTLETT

Instrument Company

1032 Avenue H

Fort Madison, IA 52627

Phone: 1(888)404-9026 Fax: (319)372-5560

www.bartinst.com

**Get social with us to keep up with
our latest deals and tips!**

