



BARTLETT Instrument Company

Valuable Information Right At Your Fingertips!

[Home](#) • [Controller Overview](#) • [GHK](#) • [RWL](#) • [CIS](#) • [W/R Alarm](#)



Did you know about your controller's hot keys that puts valuable information right at your fingertips? The hot keys can be used when your controller is in normal operation mode. The hot keys give instant access to information like maximum and minimum temperature, outputs on, statistics, and more. You are also able to temporarily change the temperature in a zone if you need to increase or decrease it for any reason. When the controller transitions to the next stage, the controller will revert back to its previous setting.

Hot Key Controls:

- Keys 1 & 3 (MIN & MAX) - check the highest and lowest temperature reached since last reset.
- Key 2 (Reset) - reset the minimum and maximum temperatures displayed by key 1 and 3.
- Keys 4 & 6 (Up 1 & Down 1) - temporarily increase or decrease the temperature in Zone 1.
- Key 5 (Z1/Z2) - In 2 zone mode, toggle between which zone's temperature is being displayed.
- Keys 7 & 9 (Up 2 & Down 2) - temporarily increase or decrease the temperature in Zone 2.
- Key 8 (Outputs) - display which outputs are currently on.
- Key 0 (Stats) - the stats key is use to select 1 of the last 7 days statistics.

As you can see, the Hot Keys can be extremely helpful when you need information fast. If you've got questions about your Bartlett controller and its operation, feel free to email or call us and we'll be happy to help!

BARTLETT

Instrument Company

1032 Avenue H

Fort Madison, IA 52627

Phone: 1(888)404-9026 Fax: (319)372-5560

www.bartinst.com

**Get social with us to keep up with
our latest deals and tips!**

